

	Reference	Model	Refrigerant	Nominal content (g)	Gwp	Co ₂ -equivalent (tonnes)	Cooling capacity (kW)	Heating capacity (kW)	Electrical capacity (kW)	Construction year	Date last checked
Airco's productie installaties	10B-00-39	RZAG35A2V1B	R-32	1550	675	1,05	3,5			2	2021 07/04/2023
Airco's productie installaties	1C-00-101/01&02	FBA125A2VEB / RZAG125M7Y1B	R-32	3750	675	2,53	12,1		3,64	2018	07/04/2023
Airco's productie installaties	1C-00-102/01&02	FBA125A2VEB / RZAG125M7Y1B	R-32	3750	675	2,53	12,1		3,64	2018	07/04/2023
Airco's productie installaties	1C-00-103	20WFMF0551CPA	R-407c	4150	1773,9	7,36				7	2020 07/04/2023
Airco's TD, CCK, burelen, labo	3B-00-45/01&02	FBQ140C7VEB / RZQS140D7V1B	R-410a	3700	2087,5	7,72	13,4		7,36	2010	05/04/2023
Airco's TD, CCK, burelen, labo	3B-00-46/01&02	FCQ35C8VEB / RKS35G2V1B	R-410a	1200	2087,5	2,5	3,4		2,3	2009	23/05/2023
Airco's TD, CCK, burelen, labo	3B-00-47	RXP35M5V1B	R-32	700	675	0,47			1	2020	05/04/2023
Airco's TD, CCK, burelen, labo	3B-00-48	RXP50M5V1B	R-32	900	675	0,61			1	2021	05/04/2023
Airco's TD, CCK, burelen, labo	3B-00-49	RXP25M5V1B	R-32	550	675	0,37			1	2019	06/04/2023
Airco's TD, CCK, burelen, labo	3D-00-100/01&02	ASHG12LMCA / AOHG12LMCA	R-410a	850	2087,5	1,77	3,4		1,02	2017	05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-47/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-52/01&02	38QHG009D8S	R-32	740	675	0,5	2,75		1,13	2021	05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-54/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-55/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-58/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-59/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-62/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-63/01&02	AOHG12KMTA / ASHG12KMTA	R-32	690	675	0,47	3,4		4	2019	05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-66/01&02	ASHG12LMCA / AOHG12LMCA	R-410a	850	2087,5	1,77	3,4		1,02	2017	04/04/2023
Airco's TD, CCK, burelen, labo	3D-00-67/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-68/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-72/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-73/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-75/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	800	2087,5	1,67	2,64		0,97	2010	14/07/2023
Airco's TD, CCK, burelen, labo	3D-00-76/01&02	38QHG012D8S	R-32	650	675	0,44	3,65		1,13	2023	20/06/2023
Airco's TD, CCK, burelen, labo	3D-00-79/01&02	G09AH / LGG09AH (AS-H0966-KA2)	R-410a	710	2087,5	1,48	2,64	3,9	0,97		05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-81/01&02	ASHG12LMCA / AOHG12LMCA	R-410a	850	2087,5	1,77	3,4		1,02	2017	05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-88/01&02	ASHG07LMCA / AOHG07LMCA	R-410a	700	2087,5	1,46	3,4		1,02	2017	05/04/2023
Airco's TD, CCK, burelen, labo	3D-00-99/01&02	ASHG12LMCA / AOHG12LMCA	R-410a	850	2087,5	1,77	3,4		1,02	2017	05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-48/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-49/01&02	G09AH / LGG09AH (AS-H0966-KA2)	R-410a	710	2087,5	1,48	2,64		0,97		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-50/01&02	G09AH / LGG09AH (AS-H0966-KA2)	R-410a	710	2087,5	1,48	2,64		0,97		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-51/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-53/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-56/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-57/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-61/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-65/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-69/01&02	ASHG12LFCA / AOHG12LFC	R-410a	1770	2087,5	3,69	5,2		1,71	2017	27/04/2023
Airco's TD, CCK, burelen, labo	3D-04-70/01&02	G09AH / LGG09AH (AS-H0966-KA2)	R-410a	710	2087,5	1,48	2,64		0,97		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-71/01&02	G09AH / LGG09AH (AS-H0966-KA2)	R-410a	710	2087,5	1,48	2,64		0,97		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-74/01&02	G09AH / LGG09AH (AS-H0966-KA2)	R-410a	710	2087,5	1,48	2,64		0,97		05/04/2023
Airco's TD, CCK, burelen, labo	3D-04-77/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		04/04/2023
Airco's TD, CCK, burelen, labo	3D-04-78/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		04/04/2023
Airco's TD, CCK, burelen, labo	3D-04-80/01&02	G18AH / LGG18AH (AS-H186TKA2)	R-410a	1270	2087,5	2,65	5,42		1,9		04/04/2023
Airco's TD, CCK, burelen, labo	3D-04-89/01&02	ASHG12LMCA / AOHG12LMCA	R-410a	850	2087,5	1,77	3,4		1,02	2017	04/04/2023
Airco's TD, CCK, burelen, labo	3D-04-90/01&02	ASHG12LMCA / AOHG12LMCA	R-410a	850	2087,5	1,77	3,4		1,02	2017	04/04/2023
Airco's TD, CCK, burelen, labo	3D-04-91/01&02	ASHG12LMCA / AOHG12LMCA	R-410a	850	2087,5	1,77	3,4		1,02	2017	05/04/2023
Airco's TD, CCK, burelen, labo	3E-00-30/01&02	SX24 / OU7-24 / 75PO1200SB	R-407c	3160	1773,9	5,61	7,04		2,6		05/04/2023
Airco's productie installaties	3E-00-31/01&02	ABAF18LBT / AOHA18LALL	R-410a	1250	2087,5	2,61	5,2		1,66	2015	05/04/2023
Airco's productie installaties	3E-00-32/01&02	ABHF24LBT / AOHA24LALL	R-410a	1700	2087,5	3,55	7,1		2,21	2015	05/04/2023
Airco's TD, CCK, burelen, labo	3J-00-36/01&02	75PO1200SB / 6C24T	R-407c	1800	1773,9	3,19	7,1		3,09		06/04/2023
Airco's TD, CCK, burelen, labo	3J-04-36/ 01&02&03&04	AOH30LMAW4	R-410a	3300	2087,5	6,89	8	9,6	2,4	2010	06/04/2023
Airco's productie installaties	3O-00-109	UUD3 U30	R-32	3000	675	2,02			3,06	2020	06/04/2023
Airco's productie installaties	3O-00-110	UUD3 U30	R-32	3000	675	2,02			3,06	2020	06/04/2023
Airco's TD, CCK, burelen, labo	3R-00-01	ASH-12BIV	R-32	590	675	0,4	3,2	3,5	1,00	2020	06/04/2023
Airco's TD, CCK, burelen, labo	3T-00-95/01&02	SRK502MX-S / SRC502MX-S	R-410a	1500	2087,5	3,13	5		1,36	2017	05/04/2023
Airco's TD, CCK, burelen, labo	3T-00-96/01&02	SRK502MX-S / SRC502MX-S	R-410a	1500	2087,5	3,13	5		1,36	2017	05/04/2023
Airco's TD, CCK, burelen, labo	3U-00-92/01&02	FTX50GV1B / RX50G3V1B	R-410a	1500	2087,5	3,13	5		1,7	2017	05/04/2023
Airco's TD, CCK, burelen, labo	3U-00-93/01&02	FTX50GV1B / RX50G3V1B	R-410a	1500	2087,5	3,13	5		1,7	2017	05/04/2023
Airco's TD, CCK, burelen, labo	3U-00-94/01&02	FTX25J3V1B / RX25K5V1B	R-410a	740	2087,5	1,54	2,5		1	2017	05/04/2023
Airco's TD, CCK, burelen, labo	3V-00-103/01&02	FTXP50M2V1B / RXP50M2V1B	R-32	900	675	0,61	5		1,82	2020	05/04/2023
Airco's TD, CCK, burelen, labo	3V-00-104/01&02	FTXP25M5V1B / RXP25M5V1B	R-32	550	675	0,37	2,5		0,65	2020	05/04/2023
Airco's TD, CCK, burelen, labo	3V-00-105/01&02	FTXP60M2V1B / RXP60M2V1B	R-32	1150	675	0,78	6		2,68	2020	05/04/2023
Airco's TD, CCK, burelen, labo	3V-00-106/01&02	FTXP60M2V1B / RXP60M2V1B	R-32	1150	675	0,78	6		2,68	2020	05/04/2023
Airco's TD, CCK, burelen, labo	3V-00-107/01&02	FTXP50M2V1B / RXP50M2V1B	R-32	900	675	0,61	5		1,82	2020	05/04/2023
Airco's TD, CCK, burelen, labo	3V-00-108	AOHG18KMTA	R-32	1020	675	0,69	5,2	6,3	1,66	2021	05/04/2023
Airco's productie installaties	4C-04-24/01&02	ARHG60LHTA / AOHG60LATT	R-410a	3450	2087,5	7,2	15		4,7	2015	19/04/2023
Airco's productie installaties	4C-04-25/01&02	ARHG60LHTA / AOHG60LATT	R-410a	3450	2087,5	7,2	15		4,7	2015	19/04/2023
Airco's productie installaties	4C-04-39/01&02	ABHA54LCT / AOHD54LATT	R-410a	3450	2087,5	7,2	14		4,65		19/04/2023
Airco's productie installaties	4C-08-37/01&02	ARG90TLC3 / AOG90TPC3L	R-410a	7100	2087,5	14,82	25,4		12,5		19/04/2023
Airco's productie installaties	4F-04-14	38QUS048D8T	R-32	2900	675	1,96	14,1	15,5	6,9		24/04/2023
Airco's productie installaties	4F-04-15/01&02	38QYS048D8T	R-32	2900	675	1,96	14	16	6,9	2022	13/04/2023
Airco's productie installaties	4F-04-16/01&02	ARHC45LCTU / AOHD45LATT	R-410a	3450	2087,5	7,2	12,5		3,89		18/04/2023
Airco's productie installaties	4F-04-17/01&02	FBA140 / RZAG140	R-32	3750	675	2,53	13,4		6,42	2018	13/04/2023
Airco's productie installaties	4F-04-18/01&02	FBA140 / RZAG140	R-32	3750	675	2,53	13,4		6,42	2018	13/04/2023
Airco's productie installaties	4F-04-19/01&02	38QYS048D8T	R-32	2900	675	1,96	14	16	6,9	2022	13/04/2023
Airco's productie installaties	4F-04-20/01&02	FBA140 / RZAG140	R-32	3750	675	2,53	13,4		6,42	2018	13/04/2023
Airco's productie installaties	4G-00-08/01&02	UPA 211	R-410a	6000	2087,5	12,52	20,1		5,39	2022	17/08/2023
Airco's productie installaties	4G-00-09/01	UPA 211	R-410a	9300	2087,5	19,41	20		5,39	2021	10/08/2023
Airco's productie installaties	4G-00-87/01&02	UPA211B / ACC25H	R-410a	9340	2087,5	19,5	21,5		6,55	2015	17/08/2023
Airco's productie installaties	4J-00-83/01&02	ARYA45LCTU / AOHA45LCTL	R-410a	3450	2087,5	7,2	12,1		3,77	2013	07/04/2023
Airco's productie installaties	4J-00-84/01&02	ARYA45LCTU / AOHA45LCTL	R-410a	3450	2087,5	7,2	12,1		3,77	2013	07/04/2023
Airco's productie installaties	6D-02-40/01&02	FHQG71C / RZQ71D3V1	R-410a	2750	2087,5	5,74	11		4,16	2011	07/04/2023
Airco's productie installaties	6D-02-41/01&02	FHQG71C / RZQ71D3V1	R-410a	2750	2087,5	5,74	11		4,16	2011	07/04/2023
Airco's TD, CCK, burelen, labo	6D-02-97/01&02	ASHG14LMCA / AOHG14LMCA	R-410a	1050	2087,5	2,19	4		3,66	2017	07/04/2023
Airco's productie installaties	7B-00-06/01&02	FBA140 / RZAG140	R-32	3750	675	2,53	13,4		6,42	2018	13/04/2023
Airco's productie installaties</											