

Stalen	Aard staal	datum staalname	Conductiviteit (µS/cm)	Nitriet (mg/l)	Nitraat (mg/l)	Sulfaat (mg/l)
WS0	spui generator, ontharder, douches (garage)	9/3/2024	2580	<0,02	17.13	133
WS1	condenswater stoom	9/3/2024	28.95	<0,02	0.28	0.18
WS2	koelwater autoclaven	9/3/2024	327	<0,02	4.49	33.68
WS3	spuiwater stoomketel	9/3/2024	2960	<0,02	28.58	306
WS4	spuiwater stoomketel	9/3/2024	2540	<0,02	22.15	368
WS5	spuiwater koeltorens	9/3/2024	1584.5	<0,02	26.77	202
WS6	lozing bandfilter en condens stoomstraat	19/9/2024				
WS7	vervuild regenwater, plantengroeikamers, condenswater stoom	9/3/2024	412.5	0.17	3.12	0.61
WS8	Grondwater HS cabine	19/9/2024				
WS9	afvalwater kikkers	9/3/2024	30.35	0.09	0.97	0.37
WS10	regenwater overloop vijver + hemelwater inrit garage	9/3/2024	147.45	<0,02	0.13	0.25
geldende voorwaarden: indelingscriteria of basismilieukwaliteitsnormen Vlarem II, bijlage 2.3.1 Art. 2 typ			1000		5.65	150