

## Emissiemetingen AZMM

	ketel 1a	ketel 1b	ketel 2a	ketel 2b
metingen datum	2/08/2023	2/08/2023	2/08/2023	2/08/2023
draaiuren/jaar	2000	2000	2000	2000
debiet rookgassen	449	487	421	383
SOx (mg/Nm <sup>3</sup> )	< 1	< 10	< 1	< 10
SOx (ton/jaar)	0,000898	0,000974	0,000842	0,000766
SOx (ton/jaar)	< 0,007	< 0,008	< 0,007	< 0,008
NOx (mg/Nm <sup>3</sup> )	30	25	32	29
NOx (ton/jaar)	0,03	0,02	0,03	0,02
CO (mg/Nm <sup>3</sup> )	6	5	5	8
COx (ton/jaar)	0,01	0,00	0,00	0,01

vwarmtevermogen	425	425	425	425	kWth
verbruik aardgas	345	345	345	345	Mwh /jaar
hoogte schouw	7	7	7	7	m
bouwjaar	2016	2016	2016	2016	