

LP AWZI

		Debiet	ZS	Chloriden	Sulfaten	BOD	COD	Ptot	Ntot	As	Nitriet	Co	V	Ni	Zn	B	AOX
		m³/d	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
			30	1500		20	100	1,5	15	0,005	0,5	0,003	0,025	0,03	0,20	0,8	0,3
2024	gemiddelde	4226,833	8,1	497,375	1321,429	1,528571	13,93571	0,923857	9,256429	0,00208	0,155357	0,000699	0,011329	0,005415	0,026415	0,114857	0,037
2024	90p	4514,5	13,69	720,5	1418	1,57	15,91	1,244	13,8	0,0025	0,3306	0,001066	0,0146	0,0073	0,03	0,1896	0,0676
2024	max	4769	28	836	1430	1,8	23,1	1,38	14,1	0,0025	0,351	0,00148	0,0158	0,0129	0,03	0,24	0,069
2024	aantal metingen	6	14	8	7	14	14	14	14	13	7	7	7	13	13	7	8
2024	aantal metingen onder DL	NVT	0	0	0	11	0	0	0	10	2	0	0	11	10	1	1
2024	aantal metingen boven norm	0	0	0	NVT	0	0	0	0	0	2	3	7	0	0	0	0
2025	gemiddelde	3723,56	9,513333	475,8		1,766667	16,24	0,377667	8,046667	0,0025				0,0045	0,03		
2025	90p	3957,48	15,2	491		2,4	20,6	0,7428	10,06	0,0025				0,0045	0,03		
2025	max	4132	34,4	497		4	46	1,08	12,2	0,0025				0,0045	0,03		
2025	aantal metingen	15	15	5		15	15	15	15	15				15	15		
2025	aantal metingen onder DL	NVT	0	0		13	2	1	0	15				15	15		
2025	aantal metingen boven norm	0	0	0		0	0	0	0	0				0	0		

MAX5000

VV (in kg/d)15075001005007,5750,0252,50,0150,1250,15141,5

INTAKE kanaalwater

		Debiet	ZS	Chloriden	Sulfaten	BOD	COD	Ptot	Ntot	As	Nitriet	Co	V	Ni	Zn	B	AOX
		m³/d	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L
2020-2025	gemiddelde		8,324138	1476,331		1,906897	16,47586	0,39169	5,022414	0,00283				0,005845		0,036045	
2020-2025	90p		12,24	3735		2,76	23,92	0,5148	6,7	0,00368				0,005378		0,0302	
2020-2025	max		15	4080		5,7	36	0,583	7,3	0,0044				0,0367		0,251	
2020-2025	aantal metingen		29	16		29	29	29	29	29				29		29	
2020-2025	aantal metingen onder DL		0	0		20	0	0	0	13				15		13	
2020-2025	aantal metingen boven norm		NVT	NVT		NVT	NVT	NVT	NVT	NVT				NVT		NVT	

MAX1864

VV (in kg/d)15,516192751,8813,55445530,711010,730119,3617790,0052760,0108950,067188

Debietsgewogen gemiddelde in mg/L (wc)686424,113661493,57215,086677,318041,19902512,290470,0044110,3642190,0021850,0182110,023440,1456880,5925390,218531

OPCONCENTRATIEFACTOR3,33

80,29854973,59650,23839257,46913,99275440,927260,0146881,212850,0072770,0606420,0780560,485141,9731550,72771

debiet in wezer2059